



984 Gorham Street, Newmarket, ON L3Y 1L8
Administration: 905-895-9222
Emergency: 9-1-1

Central York Fire Services Incident Report

Incident Type: Building Fire

Date: Tuesday, April 19, 2016

Time of Call: 9:20 p.m.

Ward: 2

Address / location of incident: 596 Davis Drive, Newmarket

Description: Central York Fire Services (CYFS) responded to a reported fire at Southlake Hospital in Newmarket. Reports from dispatch state that the fire was in the west end of the building. Upon arrival, the first Officer on scene reported smoke visible on the ground floor. Fire crews advanced hose lines and proceeded to extinguish the fire. The sprinkler system was also activated and assisted in extinguishing the fire. York Regional Police and York Paramedics were on scene for assistance. CYFS Fire Prevention Investigation and Office of the Fire Marshal have been notified.

Cause of incident: Suspected Cause, Battery Storage.

Casualties / Injuries: There are no reported injuries.

Community Impact: N/A

Current Status: The fire was extinguished by CYFS fire crews. CYFS Fire Prevention Investigation has been notified. Because the building is considered a Vulnerable Occupancy, it is legislated that it is reported to the Office of the Fire Marshal and Emergency Management Ontario.

Resources Used: CYFS worked in collaboration with York Paramedics and York Regional Police as required. No mutual aid was initiated.

For more information contact:

Wanda Bennett | Director of Communications | Town of Newmarket
Phone: 905-953-5300 ext. 2041 | Email: wbennett@newmarket.ca